

Certificate of Compliance

Certificate Number 160506 - E303865
Report Reference E303865, April 7th, 2006
Issue Date 2006 May 16

Page 1 of 1



Issued to: **HB PRODUCTS AS**
JEGSTRUPVEJ 34
8361 HASSELAGER DENMARK

*This is to certify that
representative samples of*

Class I, Division 2 Group ABCD Hazardous
Longstroke type SA96DX-I/xxx/Ex and Shortstroke type SLCD-M1/xx/Ex for
use in Class I, Division 2 Group ABCD Hazardous Locations when installed in
accordance with control drawing No. A038cULus.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

**ANSI/ISA-12.12.01-2000 - Nonincendive Electrical Equipment for use in Class I and
II, Division 2 and Class III, Divisions 1 and 2, Hazardous (Classified) Locations**
**CSA C22.2 n.213 - Non-incendive Electrical Equipment for use in Class I, Division,
Hazardous Locations**

Additional Information:

RATINGS:
For all covered Longstroke and Shortstroke versions of position transmitters
Vi: 26.5V - Ii: 116mA
Pi: 950mW - Ci: 50nF
Li: 1mH

Only those products bearing the UL Listing Mark for the US and Canada should be
considered as being covered by UL's Listing and Follow-Up Service meeting the
appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol
with "C" and "US" identifiers: the word "LISTED"; a control number (may be
alphanumeric) assigned by UL; and the product category name (product identifier) as
indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Ole Olsen*
Ole Olsen, Project Engineer

UL International Demko A/S

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Denmark, you may call +45 44856565.

Reviewed by: *Klaus M. Hansen*
Klaus M. Hansen, Project Engineer

UL International Demko A/S